# POWER GENERATION APPLICATIONS CURSOR SERIES

## **C87 TE1D**

255 kW @ 1500 rpm 276 kW @ 1800 rpm

Stage II / Tier 3

Specifications				
Thermodynamic cycle		Diesel 4 stroke		
Air intake		TAA		
Arrangement		6L		
Bore x Stroke	mm	117 × 135		
Total displacement		8.7		
Valves per cylinder		4	3	
Injection system		Electronic Common Rail		
Speed governor		Electronic		
Cooling system		liquid (water - paraflu 50%)		
Flywheel housing/flywheel	type	SAE1 / 14"		
Flywheel rotation		CCW		
Lube oil specifications		ACEA E3-E5		
Lube oil consumption		<0.2% of fuel consumption		
Fuel specifications		EN 590		
Oil and filters intervals for replacement	hours	600		
Fuel consumption at:	rpm	1500	1800	
	100% load I/h (g/kWh)	58.8 (205.4)	64.3 (204.5)	
	80% load l/h (g/kWh)	47.6 (209.3)	54 (215)	
	50% load I/h (g/kWh)	35.4 (225)	38.8 (225)	
Coolant capacity: engine only		~15		
engine+radiator	T <sub>1</sub>	~63		
ATB (without canopy)	°C	55	ma da Mat	
No remote cooling radiator allowed				
Lube oil total system capacity including pipes, filters etc.		~28	4	
Electrical system		24Vcc		
Starting batteries: recommended capacity	Ah	2 × 185		
Discharge current (EN 50342)	А	1200		
Cold starting: without air preheating	°C	-10	20 10 10 10 10 10 10 10 10 10 10 10 10 10	
with air preheating	°C	-25		

#### **Performances**

Ratings <sup>1</sup>		150	1500 rpm		1800 rpm	
		PRIME	STAND-BY	PRIME	STAND-BY	
Rated Output <sup>2</sup>	kWm	232	255	254	276	

- 1) Ratings in accordance with ISO 8528. For duty at temperature over 40°C and/or altitude over 1000 meters must be considered a power derating factor. Contact the FPT sales organization.
- 2) Net power at flywheel available after 50 hours running with a  $\pm 3\%$  tolerance.

**PRIME POWER:** The prime power is the maximum power available with varying loads for an unlimited number of hours. The average power output during a 24h period of operation must not exceed 80% of the declared prime power between the prescribed maintenance intervals and at standard environmental conditions. A 10% overload is permissible for 1 hour every 12 hours of operation.

**STAND-BY POWER:** The stand-by power is the maximum power available for a period of 500 hours/year with a mean load factor of 90% of the declared stand-by power. No kind of overloads is permissible for this use.

**CONTINUOUS POWER:** Contact the FPT sales organization.

## **C87 TE1D**

255 kW @ 1500 rpm 276 kW @ 1800 rpm

Stage II / Tier 3

### Standard configuration

FPT engine C87 TE1D equipped with:


- Mounted radiator incorporating air-to-air charge cooler
- Front radiator guard
- Oil drain pump
- Mounted belt driven pusher fan
- Fan guard
- Mounted air filter with replaceable cartridges
- Fuel filter
- Primary fuel filter/water separator
- Replaceable oil filter
- Electronic engine control unit
- Interface box
- WT and OP sensors for gauges
- HWT and LOP sensors
- Front engine mountings brackets
- Flywheel housing SAE1 and flywheel 14"
- Re-directable exhaust gas elbow
- Recirculed oil breather system
- Oil dipstick
- 24Vdc elettrical system
- User's handbook

THE ENGINE IS SUPPLIED WITHOUT LIQUIDS

## **Optional equipment:**

On request the engine can be supplied with:

- 230 Volt water jacket heater
- Turbo and exhaust gas guards
- Exhaust gas flexible joint
- Low water level sensor



#### **Overall dimensions:**

L = 2042 mm W = 1055 mm H = 1394 mm Dry weight ~ 1220 kg

Publication P4A06C004E - 01.12 Specifications subject to change without notice. Illustrations may include optional equipment.